



AMBUJA CEMENTS LIMITED. UNIT RAURI (H.P.)




**SUSTAINABLE DEVELOPMENT
(OUR CORPORATE PHILOSOPHY)**

**DAILY AVERAGE VALUES OF CONTINUOUS EMISSION
MONITORING SYSTEM INSTALLED AT RAURI PLANT FOR THE
MONTH OF JUNE, 2014**

Date	Dust (mg/Nm³)	SO₂ (mg/Nm³)	NOx (mg/Nm³)
1-Jun-14	7.35	96.78	920.02
2-Jun-14	7.38	92.08	848.14
3-Jun-14	7.65	90.72	781.70
4-Jun-14	7.46	38.37	819.37
5-Jun-14	8.68	52.78	894.83
6-Jun-14	7.78	20.70	1111.51
7-Jun-14	7.39	14.42	1061.79
8-Jun-14	7.61	12.80	1047.85
9-Jun-14	9.00	18.32	1064.13
10-Jun-14	8.40	12.14	910.24
11-Jun-14	9.56	10.53	808.89
12-Jun-14	8.22	17.16	819.21
13-Jun-14	8.84	20.70	820.03
14-Jun-14	8.43	42.09	770.15
15-Jun-14	8.10	38.24	767.32
16-Jun-14	8.34	46.37	788.85
17-Jun-14	9.12	82.47	812.24
18-Jun-14	8.83	44.14	869.42
19-Jun-14	7.93	83.47	898.59
20-Jun-14	8.32	53.18	726.24
21-Jun-14	7.85	58.06	740.86
22-Jun-14	8.77	43.64	799.63
23-Jun-14	7.76	22.73	844.10
24-Jun-14	7.25	46.72	805.88
25-Jun-14	7.89	90.87	734.01
26-Jun-14	7.89	45.39	718.64
27-Jun-14	7.94	51.05	672.82
28-Jun-14	7.90	73.17	670.92
29-Jun-14	7.38	72.42	733.73
30-Jun-14	8.04	52.15	1041.42

X: - No Daily Mean Value



THANKS

 **Holcim** **AMBUJA CEMENT**